

12 December 2020

William Cheever
5720 Reed St.
Arvada, CO 80002
cheeverwilliam@gmail.com
(720) 252-9878

Dan Canda, P.E.
J2.26 Engineering
5765 Olde Wadsworth Blvd
Arvada, CO 80002
dcanda@j226engineering.com
(720) 937-2055

RE: Onsite Observations: Foundation installation
Address: 5720 Reed St.
J2.26 Project #: 21177
Inspection Dates: 8/1/22, 8/5/22

William,

This letter is to confirm all repairs to the foundation meet or exceed the project requirements as shown in the construction/repair documents. Note, based on onsite observations and reported field conditions, J2.26 Engineering discussed adaptations to the foundation system. Specifically:


1. Existing 8" diameter post foundations were removed
2. The extent of the underpin foundation was extended
3. Wider foundation wall to ensure effective wall bearing was approved

The foundation as installed meets and/or exceeds all project requirements as set forth in the construction documents.

Final observations were made by me, or by someone under my direct supervision.

Please feel free to contact me if you have any additional questions about this report.

Regards,


Daniel M. Canda, P.E.
J2.26 Engineering, LLC



5765 Olde Wadsworth Blvd, Unit 28, Arvada, CO 80003 - www.j226engineering.com - 720.937.2055