BACKFLOW EXPERTS

1509 Osceola Street, Denver, CO 80204
Phone 303-629-0722 • Fax 303-825-1467

Assembly Serial # 231107
Test Date / Time 10-12-23
Tester Certification # 10424
Assembly Test Results ☒ Pass ☐ *Fail
☐ Under Suspension - Process Immediately

Denver Water Backflow Assembly Test & Maintenance Report *(please print CLEARLY with* **BLOCK LETTERING***)*

Account

Business Name: Arvada Place Apartments
Facility Address: 9225 West 57th Avenue City: Arvada CO 80002
Contact Person: Desiree Carlin Phone: 720-651-7445

Assembly

Make: Watts Model: LF009M2QT
Type: ☒ RP ☐ DC ☐ PVB ☐ Air Gap
Size: 2" Date Installed:
☒ New ☐ Existing
Previous Assembly #:
Location: In SE corner Fire Riser Room

Type Of Use
☒ Domestic
☐ Fire ☐ Glycol
☐ Irrigation
☐ Recycled
Supplies:

Orientation
Inlet: ☒ Horizontal
Outlet: ☒ Horizontal ☐ Vertical Up ☐ Vertical Down

Testing & Maintenance

Line PSI: 80	Initial Test		Repairs		Retest
Check Valve #1 (RP, DC, PVB)	85				
Check Valve #2 (RP, DC)	1.8				
Relief Valve (RP)	3.2				
Buffer (RP)					
Air Inlet (PVB)					

Test Procedure: ABPA ASSE 1013

Comments

Comments/Issues:

Test Kit

Test Kit Make: Mid West Model: 845
Serial #: 03201609 Last Calibration Date: 12-13-22

Tester

Testing Company: Backflow Experts
Tester Name: Rich Overholser Phone: 303-629-0722
Signature: Rich Overholser Certificate Expiration Date: 2-29-24

Testing Company: Submit by e-mail (preferred) to CrossConnectionControl@denverwater.org, type "Backflow Test Reports" in the subject line OR submit by Fax to (303) 794-8325.

* ***FAILED*** *test results* ***must*** *be reported to Denver Water within 24 hours of failure at (303) 628-5969.*

BACKFLOW EXPERTS

1509 Osceola Street, Denver, CO 80204
Phone 303-629-0722 • Fax 303-825-1467

Assembly Serial # T467977
Test Date / Time 10-12-23 8:24
Tester Certification # 10424
Assembly Test Results [X] Pass [ ] *Fail
[ ] Under Suspension - Process Immediately

Denver Water Backflow Assembly Test & Maintenance Report *(please print CLEARLY with* **BLOCK LETTERING***)*

Account

Business Name: Arvada Place Apartments
Facility Address: 9225 West 57th Avenue City: Arvada CO 80002
Contact Person: Dezirae Carlin Phone: 720-651-1445

Assembly

Make: Wilkins Model: 720A
Type: ☐ RP ☐ DC ☒ PVB ☐ Air Gap
Size: 3/4" Date Installed:
☒ New ☐ Existing
Previous Assembly #:
Location: out SE corner of Building

Type Of Use
☐ Domestic
☐ Fire ☐ Glycol
☒ Irrigation
☐ Recycled
Supplies:

Orientation
Inlet Outlet
☐ Horizontal ☒
☒ Vertical Up ☐
☐ Vertical Down ☐

Testing & Maintenance

Line PSI: 83	Initial Test		Repairs		Retest
Check Valve #1 (RP, DC, PVB)	2.7				
Check Valve #2 (RP, DC)					
Relief Valve (RP)					
Buffer (RP)					
Air Inlet (PVB)	4.5				

Test Procedure: ABPA ASSE 1020

Comments

Comments/Issues:

Test Kit

Test Kit Make: Mid West Model: 945
Serial #: 03201609 Last Calibration Date: 12-13-22

Tester

Testing Company: Backflow Experts
Tester Name: Rich Overholser Phone: 303-629-0722
Signature: Rich Overholser Certificate Expiration Date: 2-28-24

Testing Company: Submit by e-mail (preferred) to CrossConnectionControl@denverwater.org, type "Backflow Test Reports" in the subject line OR submit by Fax to (303) 794-8325.

* ***FAILED*** *test results* ***must*** *be reported to Denver Water within 24 hours of failure at (303) 628-5969.*