

Jordan & Skala Engineers



Atlanta | Austin | Charlotte | Dallas | DC | Denver | Houston | Las Vegas

July 12, 2023

Justin Clark
City of Arvada Building Dept.
8101 Ralston Rd.
Arvada, CO 80002

Re: Morgan Ralston Creek – Clubhouse Mechanical Revisions

Dear Justin:

The following are revisions to the plans for the subject project. All revisions are clouded with a Delta 7 and labeled Clubhouse Mechanical Revisions.

Mechanical:

M2-C21

- Revised duct sizes and routing to fit around the building structure on the First and Second Floor plans.
- Revised some diffuser sizes to fit between the building structure on the First and Second Floor plans.

M2-C22

- Revised the duct routing on the RTU 1-2, 1-3 and 1-4 to a horizontal side discharge configuration.

Please feel free to contact our office if you have any questions.

Sincerely,

JORDAN & SKALA ENGINEERS, INC.

Brett Wixson

Brett Wixson

