

# Jordan & Skala Engineers

Atlanta | Austin | Charlotte | Dallas | DC | Denver | Houston | Las Vegas

Aug. 3, 2023

Nathan Romero  
City of Arvada Building Dept.  
8101 Ralston Rd.  
Arvada, CO 80002

Re: Morgan Ralston Creek – Clubhouse Mechanical Plan Review

Dear Nathan:

JSE received an email from KTG Y (Architect of Record) regarding the request from you for a revised ComCheck for the Clubhouse. The drawing revision that was submitted was to some show updated ductwork sizing, routing and shifting a couple of rooftop units due to structural obstructions. The mechanical equipment schedules were not revised and remain unchanged from the original permit submittal and energy model. We should not have any energy model revisions to make on it. Please advise if you need anything else from us on it.

Please feel free to contact our office if you have any questions.

Sincerely,  
JORDAN & SKALA ENGINEERS, INC.

*Brett Wixson*

Brett Wixson, Brad Jacobsen

