



# Generated by REScheck-Web Software Compliance Certificate

Project Ralston II Unit C- (no party wall) 10594 W 63RD LANE

Energy Code: **2018 IECC**  
Location: **Arvada, Colorado**  
Construction Type: **Single-family**  
Project Type: **New Construction**  
Conditioned Floor Area: **1,940 ft<sup>2</sup>**  
Glazing Area: **14%**  
Climate Zone: **5 (6158 HDD)**  
Permit Date:  
Permit Number:

Construction Site:

Owner/Agent:

Designer/Contractor:

Andrew Wildenberg  
e3 Power  
1616 17th ST Suite 383  
Denver, CO 80202  
303-292-1233  
andy@e3power.net

## Compliance: Passes using UA trade-off

Compliance: **2.6% Better Than Code** Maximum UA: **228** Your UA: **222**

The % Better or Worse Than Code Index reflects how close to compliance the house is based on code trade-off rules.  
It DOES NOT provide an estimate of energy use or cost relative to a minimum-code home.

Slab-on-grade tradeoffs are no longer considered in the UA or performance compliance path in REScheck. Each slab-on-grade assembly in the specified climate zone must meet the minimum energy code insulation R-value and depth requirements.

## Envelope Assemblies

Assembly	Gross Area or Perimeter	Cavity R-Value	Cont. R-Value	Prop. U-Factor	Req. U-Factor	Prop. UA	Req. UA
Ceiling: Flat Ceiling or Scissor Truss	1,203	21.0	28.0	0.020	0.026	24	31
Front Wall: Wood Frame, 16" o.c.	493	21.0	0.0	0.057	0.060	20	21
Door: Solid Door (under 50% glazing)	24			0.140	0.300	3	7
Door 1: Glass Door (over 50% glazing)	45			0.550	0.300	25	14
Window: Vinyl Frame	30			0.300	0.300	9	9
Window 1: Vinyl Frame	6			0.300	0.300	2	2
Window 2: Vinyl Frame	30			0.300	0.300	9	9
Rear Wall: Wood Frame, 16" o.c.	198	21.0	0.0	0.057	0.060	8	9
Window: Vinyl Frame	25			0.300	0.300	8	8
Window 1: Vinyl Frame	25			0.300	0.300	8	8
Right Wall: Wood Frame, 16" o.c.	886	21.0	0.0	0.057	0.060	44	47
Door: Solid Door (under 50% glazing)	24			0.300	0.300	7	7
Door 1: Glass Door (over 50% glazing)	24			0.300	0.300	7	7

Assembly	Gross Area or Perimeter	Cavity R-Value	Cont. R-Value	Prop. U-Factor	Req. U-Factor	Prop. UA	Req. UA
Window: Vinyl Frame	10			0.300	0.300	3	3
Window 1: Vinyl Frame	8			0.300	0.300	2	2
Window 2: Vinyl Frame	15			0.300	0.300	5	5
Window 3: Vinyl Frame	10			0.300	0.300	3	3
Window 4: Vinyl Frame	10			0.300	0.300	3	3
Window 5: Vinyl Frame	5			0.300	0.300	2	2
Garage Wall: Wood Frame, 16" o.c.	198	21.0	0.0	0.057	0.060	10	11
Door 2: Solid Door (under 50% glazing)	21			0.300	0.300	6	6
Floor above Garage: All-Wood Joist/Truss	429	30.0	0.0	0.033	0.033	14	14
Floor: Slab-On-Grade (Unheated) Insulation depth: 2.0'	67		10.0	0.540	0.540	0	0

*Compliance Statement:* The proposed building design described here is consistent with the building plans, specifications, and other calculations submitted with the permit application. The proposed building has been designed to meet the 2018 IECC requirements in REScheck Version : REScheck-Web and to comply with the mandatory requirements listed in the REScheck Inspection Checklist.

Andy Wildenberg - e3 Power

Name - Title

*Andrew Wildenberg*

Signature

11.15.2021

Date