



ALL CITY INSULATION, LLC.  
3802 WRIGHT CT. WHEAT RIDGE, CO. 80033  
OFFICE: 720-240-6736 FAX: 303-431-0425  
EMAIL: [KLEWIS@ALLCITYINSULATION.COM](mailto:KLEWIS@ALLCITYINSULATION.COM)

DATE: 9-30-2022

## CERTIFICATE OF INSULATION

TO: PROMINENT PROPERTIES.

JOB ADDRESS: 8500 W. 62<sup>ND</sup> AVE. UNIT G.

### **JOB DESCRIPTION:**

INACCESSABLE CEILING @ 2X8 3 <sup>RD</sup> FLOOR (7" CLOSED CELL)	R-49 CLOSED CELL
INACCESSABLE CEILING @ 2X12 (3" CLOSED CELL + R-30 BATT)	R-50 HYBRID SYSTEM
EXTERIOR 2X6 WALLS (2X6 WALLS)	R-23 NET BLOW FIBERGLASS
PARTY WALLS (WILL NOT MEET STC 60 PER PLAN ALONE, NEED HELP WITH ENTIRE ASSEMBLY)	R-13 UNFACED BATT
RIM JOISTS (1" CLOSED CELL + R-19 UNFACED BATT)	R-26 HYBRID SYSTEM
GARAGE CEILING UNDER LIVING (1" CLOSED CELL FOAM + R-30 UNFACED BATT)	R-36 HYBRID SYSTEM
GARAGE CEILING UNDER LIVING @ INACCESSABLE SOFFIT (FILL SPACE)	R-50 NET/BLOW
OVERHANGS (1" CLOSED CELL FOAM + R-30 UNFACED BATT)	R-36 HYBRID SYSTEM
CRAWL SPACE DRAPE 3 SIDES @ EXTERIOR	R-19 VINYL DRAPE
CRAWL POLY 6 MIL POLY	6 MIL BLACK POLY
FOAM DRAFTSTOP PACKAGE	FOAM/FIBERGLASS
POLY @ EXTERIOR WALLS	4 MIL POLY

**THIS LETTER IS TO CERTIFY THAT THE INSULATION OF THE STATED ABOVE JOB ADDRESS HAS BEEN INSTALLED AND IS IN CONFORMANCE WITH THE REQUIREMENTS OF THE 2018 INTERNATIONAL ENERGY CONSERVATION CODE.**

THANK YOU,



KENNY LEWIS