

October 7, 2022

8500 W 62nd Ave Unit G
Arvada, Colorado 80004

Re: Blower Door Test for 8500 W 62nd Ave Unit G

To whom it may concern:

E3 Power performed a blower door test on the above-mentioned building on October 7, 2022, at 9:00 AM. The volume of the building was calculated to be 22,469 cubic feet. The final blower door number was 923 CFM @-50 pascals achieving an **ACH of 2.46**.


The building meets the air tightness requirement and is compliant with code.

Weather conditions: 40 degrees, Wind 5 MPH, light fog, 93% humidity.

Site Conditions:

1. Exterior windows and doors, fireplace and stove doors were closed, but not sealed, beyond the intended weather stripping or other infiltration control measures;
2. Dampers including exhaust, intake, makeup air, backdraft and flue dampers were closed, but not sealed beyond intended infiltration control measures;
3. Interior doors were open;
4. Heating and cooling systems were turned off; and
5. Supply and return registers were fully open.

Sincerely,



Jessica W. Kurela (e3 power)
303-292-1233
Building Analyst (BPI)