

Intumescent Observation



CLIENT: Lerner NPO
 FIELD REPRESENTATIVE: W. Mac
 DATE OF OBSERVATION: Dec 11 2023 TIME: 5:30
 WEATHER CONDITIONS: Mostly Sunny

PROJECT NO: DW 49791.900 - 305
 SUBDIVISION: Whisper Village Townhomes FILING: _____
 ADDRESS: 14520 W 90th Drive
 LOT: 3 BLOCK: Unit C

Recommended Foundation System

SOILS REPORT BY: GR
 PROJECT NO: DW 49791-12021
 DATED: April 21 2022

Product: No Burn
 APPLICATOR COMPANY/NAME: _____
 DATE APPLIED: prior to Insp
 MEASURED WET DRY


Description of Area Applied: FLOOR I-JOISTS
 REQUIRED MILS
 FLOOR: 9
 I-JOISTS: 9

APPROXIMATE AREA TREATED: 352 (FEET-SQUARED)
 SUBSTRATE: wood

A	B	C	D	E
9	17	9	15	9
F	G	H	I	J
K	L	M	N	O
P	Q	R	S	T
U	V	W	X	Y

Remarks: _____

Basement Layout



*INDICATES APPROXIMATE LOCATION AND MIL THICKNESS MEASUREMENTS

- IN GENERAL CONFORMANCE WITH MANUFACTURER'S SPECIFICATIONS AND REQUIREMENTS
- REJECTED; ADDITIONAL OBSERVATION REQUIRED



REVIEWED BY _____